LIST OF MATERIALS

1. RING AND COVER – J'MARK NO. J–2290 (81 LBS.) OR APPROVED EQUAL WITH INTERNAL FROST LID.
2. METER PIT – ARCO NO. 24–4 PRECAST MANHOLE (24" DIA.) OR APPROVED EQUAL.
3. SERVICE LINE – COPPER TUBING TYPE K, SAME DIAMETER AS THE METER.
4. METER YOKE ASSEMBLY – FORD 80 SERIES COPPER SETTER OR APPROVED EQUAL.
5. SHUT–OFF VALVE.
6. CORPORATION STOP. A SADDLE MAY BE REQUIRED.

ADDITIONAL NOTES

1. THE AUTHORITY SHALL INSPECT FROM THE MAIN TO THE BUILDING PRIOR TO BACKFILLING.
2. IF THE SURFACE IS NOT TO FINAL GRADE AT THE TIME OF THE METER INSTALLATION, THE PROPERTY OWNER SHALL RAISE OR LOWER THE METER PIT ACCESS MANHOLE TO MATCH THE FINAL GRADE.
3. THE METER SHALL BE A POSITIVE DISPLACEMENT ROCKWELL OR NEPTUNE TRIDENT 8, READING IN GALLONS.
4. CAP TYPE TOP LID SHALL BE CAST IRON ONLY. THE INNER LID SHALL BE CAST IRON, ALUMINUM OR RUBBER. THE ALUMINUM SHALL BE COATED WITH A POLYMER SUCH AS EPOXY. CAST IRON SHALL BE COATED WITH AN ASPHALT BASE PAINT.

ELBERT COUNTY	STANDARDS & SPECIFICATIONS	REVISED:	OUTSIDE SETTING 1' METERS AND BELOW
DATE:		DRAWING NO. 200–13	